

**661—205.15(100) Intermediate care facilities for persons with intellectual disabilities and intermediate care facilities for persons with mental illness.**

**205.15(1)** *New intermediate care facilities.* New intermediate care facilities for persons with intellectual disabilities and new intermediate care facilities for persons with mental illness shall comply with the provisions of one of the following:

- a. NFPA 101, Life Safety Code, 2012 edition, Chapter 18.
- b. NFPA 101, Life Safety Code, 2012 edition, Chapter 32.

**205.15(2)** *Existing intermediate care facilities.* Existing intermediate care facilities for persons with intellectual disabilities and existing intermediate care facilities for persons with mental illness shall comply with the provisions of one of the following:

- a. NFPA 101, Life Safety Code, 2012 edition, Chapter 19.
- b. NFPA 101, Life Safety Code, 2012 edition, Chapter 33.

NOTE: Any requirement contained in Chapter 33 that is determined on a rating of evacuation capability shall be based upon an evacuation capability rating of “impractical.” Any provision which depends upon an evacuation rating of “prompt” or “slow” shall be unavailable.

[ARC 3526C, IAB 12/20/17, effective 1/24/18]